

Northantsfire

Certificate

NORTHANTS FIRE LTD
17 Osyth Close
Brackmills Ind Est
Northampton
NN4 7DY

Tel: 01604 760600

On 24/11/2025 have serviced the

FIRE APPLIANCES
in accordance with BS 5306:Part 3
as detailed in Inspection Report 36340

WHILTON MILL SMALL TRACK
WHILTON MILL
NR. DAVENTRY
NORTHANTS
NN11 2NH

CO2 EXTINGUISHER..	4	DRY POWDER EXTING.	9
FIRE BLANKET.....	2	LITHIUM EX.....	2
Q WATER TYPE.....	8		

Please note that non conforming or unsatisfactory
appliances are shown on Site Exception Report 36340

Portable fire extinguishers should be checked at least once every month for signs of discharge / lost / pressure / damage / correct location.
Any portable extinguishers that do not conform to the requirements, not found or serviced or any additional extinguishers required
to ensure that the level of cover at the detailed premises is at least sufficient and where applicable in accordance with BS5306-8 are
detailed in the inspection report. It is the responsible person's obligation under fire legislation to provide appropriate
levels of fire fighting equipment at all times.



Signed (for NORTHANTS FIRE LTD)



This certificate should be retained by customer and is issued in conjunction with the inspection report.

17 Osyth Close, Brackmills Industrial Estate, Northampton NN4 7DY

Telephone: (01604) 760600 Email: info@northantsfire.co.uk www.northantsfire.co.uk