

PORTABLE FIRE EXTINGUISHERS SERVICE REPORT

Certificate Number:

277715

1 DETAILS OF THE CLIENT

Client: CUMBRIA KART RACING CLUB
Address: Kelton Head Quarry, Rowrah , Frizington, CA26 3XU

2 DETAILS OF THE INSTALLATION ADDRESS

Installation Address: CUMBRIA KART RACING CLUB, Kelton Head Quarry, Rowrah , Frizington, CA26 3XU

3 PORTABLE FIRE EXTINGUISHERS

No.	Location	Make	Type	Fire Class	Capacity	Working Codes	Due Date
1	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
2	For Use On Track Events	FIREXO	ALL FIRES	34B 113B 75F	6LTR	Basic Service	01/05/2030
3	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
4	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2026
5	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
6	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
7	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030


4 ADDITIONAL COMMENTS

Site does not align with BS5306 recommendations. Please find a quotation with my recommendations. Cafe area approx 220m2. Office area approx 100m2. LH shed area approx 140m2. FRA and fire logbook unavailable at time of service.

5 DETAILS OF THE CONTRACTOR

Trading Title: UK Safety Management LTD
Address: Unit 5, Temple Point
Bullerthorpe Lane
Leeds
LS15 9JL
Registration Number (if applicable): 8817304
Telephone Number: 0113 823 1773

For the Testing and Inspection of the Portable Fire Extinguishers:

Name: Jack Brett Position: Engineer Signature:  Date: 25/03/2026

3 PORTABLE FIRE EXTINGUISHERS (CONTINUED)

No.	Location	Make	Type	Fire Class	Capacity	Working Codes	Due Date
8	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
9	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
10	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
11	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
12	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
13	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
14	For Use On Track Events	FIREXO	ALL FIRES	34A 113B 75F	6LTR	Basic Service	01/05/2030
15	For Use On Track Events	POWERX	DP	27A 144B C	6KG	Basic Service	01/03/2029
16	For Use On Track Events	POWERX	DP	27A 144B C	6KG	Basic Service	01/03/2029
17	For Use On Track Events	POWERX	DP	27A 144B C	6KG	Basic Service	01/03/2029
18	For Use On Track Events	POWERX	DP	27A 144B C	6KG	Basic Service	01/03/2029
19	Cafe Entrance Foyer	COMMANDER	DP	21A 89B C	4KG	Basic Service	01/03/2029
20	Cafe Rh Fire Exit Mounted With Id Sign	POWERX	DP	27A 144B C	6KG	Basic Service	01/03/2029
21	Cafe Entrance Seating Area Mounted With Id Sign	FIREPOWER	DP	43A 233B C	9KG	Corrective Action Required - Due Test	01/01/2026
22	Cafe Adjacent To Kitchen Mounted With Id Sign	FIREPOWER	F	13A 144B	6LTR	Corrective Action Required - Due Test	01/01/2026
23	Cafe Kitchen Mounted With Id Sign	PJ FIRE	Co2	34B	2KG	Basic Service	01/02/2031

Definition of Types:

Co2 - Carbon Dioxide
W - Water

DP - Dry Powder
WM - Water Mist

F - Foam
WC - Wet Chemical

FB - Fire Blanket

3 PORTABLE FIRE EXTINGUISHERS (CONTINUED)

No.	Location	Make	Type	Fire Class	Capacity	Working Codes	Due Date
24	Cafe Kitchen Mounted With No Id Sign	TOTAL	WC	5A 40F	2LTR	Corrective Action Required - Due Test	01/03/2026
25	Office Electrical Room Mounted With Id Sign	POWERX	DP	27A 144B C	6KG	Corrective Action Required - Due Test	01/03/2026
26	Office Race Control Room Mounted With Id Sign	FIREPOWER	DP	34A 233B C	6KG	Basic Service	01/02/2028
27	Office Signing On Office Mounted With Id Sign	POWERX	DP	27A 144B C	6KG	Basic Service	01/03/2030
28	Spare	FIREPOWER	DP	34A 233B C	6KG	Corrective Action Required - Due Test	01/03/2026
29	Spare	COMMANDER	DP	21A 89B C	4KG	Basic Service	01/03/2029
30	Spare	POWERX	DP	UNKNO WN	4KG	Condemned - Faded Information Labelling	N/A
31	Spare	COMMANDER	DP	21A 89B C	4KG	Condemned - Damaged	N/A
32	Spare	POWERX	DP	27A 144B C	6KG	Condemned - Low Pressure	N/A
33	Spare	COMMANDER	DP	21A 89B C	4KG	Condemned - Damaged	N/A
34	Lh Shed Free Standing With No Id Sign	COMMANDER	DP	21A 89B C	4KG	Basic Service	01/03/2029
35	Spare	COMMANDER	DP	21A 89B C	4KG	Condemned - Faded Information Labelling	N/A
36	Rh Shed Mounted With No Id Sign	POWERX	DP	27A 144B C	6KG	Basic Service	01/03/2029
37	Rh Shed Mounted With No Id Sign	COMMANDER	DP	21A 89B C	4KG	Basic Service	01/03/2029
38	External Mounted With No Id Sign	COMMANDER	DP	21A 89B C	4KG	Condemned - Faded Information Labelling	N/A

Definition of Types:

Co2 - Carbon Dioxide	DP - Dry Powder	F - Foam	FB - Fire Blanket
W - Water	WM - Water Mist	WC - Wet Chemical	

